

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Monitoring Reporting Requirements Not Met for
Beverly, Town of WV3304202

Our water system violated drinking water monitoring requirements. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation.

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During periods listed in the table below, we did not monitor or test as required and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

At this time, there is nothing you need to do.

The table below lists the monitoring we did not conduct, other violations, and the associated compliance period.

Monitoring Violation	Year-Fed Report #	Monitoring Frequency	Compliance Period
03, MONITORING, ROUTINE MAJOR NITRATE (NO3) Results Not Submitted	2023-13050	Yearly	YR 2023
03, MONITORING, ROUTINE MAJOR VOLATIL ORGANIC COMPOUNDS (VOC) Results Not Submitted	2023-12791	Yearly	YR 2022
27, MONITORING, ROUTINE (DBP), MAJOR Failure to monitor for Haloacetic Acids (HAA5's)	2023-12401 2022-12226	Quarterly	3 rd Q 2022 1 st Q 2022
27, MONITORING, ROUTINE (DBP), MAJOR Failure to monitor for Trihalomethanes (TTHM's)	2023-12378 2022-12206	Quarterly	3 rd Q 2022 1 st Q 2022
3A, MONITORING, ROUTINE, MAJOR (RTCR) Valid Compliance Total Coliform Sample(s) Not Reported	2023-397498	Monthly	SEP 2022
38, MONITORING, ROUTINE, MAJOR, TURBIDITY Insufficient Readings or Results Not Reported	2022-397494	Monthly	JUNE 2022

What happened? What is being done? (Describe corrective action)

See attachment.

For more information, please contact Jeremy White at 304-636-5378
(Contact Name) (Phone Number)
 or 5 Walnut Ave. Beverly, WV 26253
(Mailing Address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Prepared: 11/7/2023

Date Distributed 12/21/2023

Attachment

2023-13050— A sample for nitrate was required to be submitted within the first quarter of 2023 however the sample was not taken until April 12th of 2023. Results were reported May 1st 2023. The sample was within acceptable levels.

2023-12791— A sample for Volatile Organic Compounds was required to be submitted within the calendar year of 2022. The sample was taken on April 20th 2022 but was not submitted. The sample was within acceptable levels.

2023-12401/2022-12226/2023-12378/2022-12206— Required sampling for TTHMs and HAA5s were collected and submitted in the 1st and 3rd quarter as required, the samples were collected at the proper physical location however the address of the residence where they were collected was improperly reported. The sample was within acceptable levels.

2023-397498— Total Coliform samples require the Chlorine residual at the time of collection to be reported on the chain of custody that accompanies the sample to the lab. The chlorine residual was noted on the chain of custody but was not reported by the lab at the time of analysis and was later added. The sample showed absent for total coliform and e-coli.

2022-397494— The Operator whom submitted the turbidity report for the month failed to sign and date it. A sufficient number of readings were collected and were within acceptable levels.